

# Certificate

**SEIT/2021/16**

Report no. / Validity remark: KKL-2026-005 / 01.2026 - 01.2027

## Confirmation of Product Characteristics

In accordance with the certification scheme TNS-KKL of the Test Laboratory for Ventilation, Air Conditioning and Refrigeration of TÜV NORD Systems, this certificate applies to

**Air Handling Unit in hygienic version (H-AHU)**

placed on the market under the name or trade mark

**TAH in hygienic version**

by

**Trosten Industries Co. LLC.****Dubai Investment Park I****Dubai, UAE**

This certificate confirms that the requirements placed on the product are met. The following performance data was verified as part of the type approval test:

**Hygienic characteristics set through**

- DIN 1946-4:2018
- VDI 6022-1:2018

Technical details and application limits of the certification are specified in the scope of the certificate. This certificate remains valid as long as neither the provisions in the underlying technical specifications, the product nor the manufacturer's manufacturing conditions change significantly, but for a maximum of the end of the validity date, unless the certificate is suspended or withdrawn by the product certification body. Annual surveillance in accordance with the certification scheme is a prerequisite.

Essen, 13.02.2026

**TÜVNORD**Digitally signed by Steimle Monika  
Date: 2026.02.13 14:30:47 +01'00'

Certification Body

**TÜV NORD Systems GmbH & Co. KG**Große Bahnstraße 31, 22525 Hamburg, Germany  
tuev-nord.com | pruefstellekkl@tuev-nord.de